



VISUAL INSPECTION REPORT

Job Details

Table with 2 columns: Field Name and Value. Fields include Client, Project Name, P.O. Number, Location, Installation, Date of Inspection, Report No, AG IRM Project No, Module, Component ID, Component Type, Material, Design Temperature, Operating Temp, Design Pressure, Operating Pressure, Rep Line, Corrosion Loop, Line From, Line To, and P&ID.

Inspection Summary

Table with 3 columns: Isometric Index, Results, and Rectification WO No. Multiple empty rows for data entry.

External Inspection Checklist for Process Piping

16-AC123-67-CW-3001-V

Section 1 - Structural

- a) Check and ensure expansion joints are not bent out of shape.
b) Check for any dents and misalignments, overhung, inadequate support and vibration that can cause rupture.

Table with 3 columns: Status, Discrepancy, Photo ref. Row 1: n/a, N/A, N/A. Row 2: checkmark, No discrepancy, N/A.

Section 2 - Piping Supports

- a) Check for missing supports that can cause the pipe to rupture under weight.

Table with 3 columns: Status, Discrepancy, Photo ref. Row 1: checkmark, No discrepancy, See photo pages.

Section 3 - Coating

- a) Assess the coating condition of the piping system.

Table with 3 columns: Status, Discrepancy, Photo ref. Row 1: X, Damage coating, See photo pages.

Section 4 - Leaks

- a) Check for leaks and identify locations.

Table with 3 columns: Status, Discrepancy, Photo ref. Row 1: checkmark, No discrepancy, na.

Section 5 - Corrosion

- a) Identify corroded areas and record them. Take measurements and record pit depth.

Table with 3 columns: Status, Discrepancy, Photo ref. Row 1: checkmark, Coating damage, See photo pages.

Section 6 - Insulation and Insulation Penetrations

- a) Ensure all cladding is sealed.
b) Seal all exposed areas.
c) Expose some insulation to check the pipe surface for corrosion.

Table with 3 columns: Status, Discrepancy, Photo ref. Row 1: n/a, N/A, N/A. Row 2: n/a, N/A, N/A. Row 3: n/a, N/A, na.

Section 7 - Small Bore Attachments

- a) Ensure all small bore attachment are not vibrating or cracking.

Table with 3 columns: Status, Discrepancy, Photo ref. Row 1: checkmark, No discrepancy, N/A.

Section 8 - Threaded Plugs

- a) Check condition of threaded plugs to ensure they are not corroded.

Table with 3 columns: Status, Discrepancy, Photo ref. Row 1: X, Corroded U bolt and nut, See photo pages.

Legend

- Status checkmark : Drawing as per actual condition, no anomaly
Status X : Drawing as per actual condition, found anomaly
Status n/a : Not exist at drawing and actual condition, no access for inspection

Comments

- 1. External visual inspection was performed in accordance with API 570-2016, with the findings detailed in this report. The piping was online and at elevated temperature at the time of inspection. Comments as follow: Generally all piping segment was visually in a sound condition with no cracking, leaking, bulging, distortion, or mechanical damage present.
2. Generally all piping segment was visually in a sound condition with no cracking, leaking, bulging, distortion, or mechanical damage present
3. Observed carbon steel studs/bolt/nuts bolted on stainless steel flanges. Recommended to apply apply insulation kit and washer on carbon steel studs/nuts to prevent further galvanic corrosion
4. External corrosion
- Some corrosion observed at studs bolts/nuts either U-bolt or pipe support (P2, P4, P5)
- Sign of rust observed on surface P3, sign of deteriorated.
- Corroded flange bolts/nuts (P5)
recommend : remove rust/surface corrosion and to apply proper protective coating based on ASME Sect 1 and coating codes and to apply proper protective coating based on ASME Sect 1 and coating codes, recommend to replace corroded bolts/nuts at valve P3B.
5. Due to above condition of the piping system, recommend to replace the existing corroded pipe/fitting with same material as stated in the MDR.
6. It is recommended to measure the depth at all pitting corrosion to perform further assesment.
7. It is recommended to label/tagging the piping line so that it can be easily traced and identified.
8. Perform external inspection in a regular basis (every 5 years) as per API 570.

Table with 4 columns: API Inspector, Name, Qualification, Signature. Row 1: API Inspector, Ercarter E. Silalahi, API 570/API 510, [Signature]



VISUAL INSPECTION REPORT

Photographic Support

General view at Line pipe



Fig. 1

Surface corrosion on bolt and stud at P1



Fig. 2

Surface corrosion on U bolt at P5



Fig. 3

Surface corrosion on bolt and stud at P5



Fig. 4

Good condition at P5



Fig. 5

Good condition at P6



Fig. 6

Surface corrosion on bolt and stud at P6



Fig. 7

Surface corrosion on bolt and stud at P7



Fig. 8

Good condition at E8



Fig. 9

Good condition at T10



Fig. 10

Good condition at P13



Fig. 11

Good condition at P15



Fig. 12

Good condition at P15



Fig. 13

Good condition at P15



Fig. 14

Good condition at T17



Fig. 15

Good condition at T20



Fig. 16

Good condition at P22



Fig. 17

Good condition at P25



Fig. 18

Good condition at P25



Fig. 19

Good condition at P29



Fig. 20

Good condition at P30



Fig. 21

Good condition at P30



Fig. 22

Good condition at T32



Fig. 23

Good condition at P33



Fig. 24



PT. AG IRM SERVIS INDONESIA



ABS In-Water Specialist

Cert No. 21-4655696-A

ABS ESP Hull Gauging

Cert No. 21-4655692-A

ABS Remote Inspection Techniques

Cert No. 21-4996595-A

SKUP MIGAS NDT ★★ ★

VISUAL INSPECTION REPORT

Isometric

